

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Santa Fe County West Sector Failed to Submit Corrective Action Within Required Time Frame.

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda

Our water system recently violated a drinking water requirement. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we are doing to correct this situation.

An inspection conducted on July 21, 2017 by the New Mexico Environment Department-Drinking Water Bureau (NMED-DWB) found one significant deficiency as follows:

1. (004C) Inadequate Operations and Maintenance Plan

We were to correct the significant deficiency by September 4, 2017. However, we failed to correct the significant deficiency by this deadline.

What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours.

What is being done?

An Operations and Maintenance Plan for the Santa Fe County West Sector water system has been submitted to the New Mexico Environment Department's Drinking Water Bureau for approval. Once approved, the deficiency will be resolved.

What is being done?

We anticipate resolving the problem within the next 30 days or by July 13, 2018.

For more information, please contact:

Ted Chlastawa at 505-992-3045
Santa Fe County West Sector, NM3500826
424 NM Highway 599 Frontage Road
Santa Fe, NM 87507

****Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.****